RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 23/10/2026

Area: WT

Equipment	Job
OP-10	PLC COMPLAIN RECTIFIED AND PUSHER TESTED IN REMOTE AND LOCAL BOTH
OP-5	PANEL AND MOTOR SIDE PPM DONE D-4 MOTOR NOT IN CKT
OP-3	MOTOR AND PANEL SIDE PPM DONE D-6 MOTOR BED DOWN INFORMED MECH.