# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 22/10/2026

Area: CHP

| Equipment | Job |
|---|---|
| CC 9 | Motor replacement job under progress |
| CC 9 | Vaccume contactor replaced,OLR module bus bars replaced with jumpers,damaged finger contacts replaced |
| SCR 8,9,10 | Instrumentation sensors and Belt scale units maintenance done |
| Reclaiming streams | All Hoists UP limits tested |
| CC 125 | BRS Canopy fabricated and welded ,kept in ckt |
| CC 45,113A,132,Transfer car | PPM was done |
| Coal complex,LC 17 | Rooms cleaning done |