वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 22/10/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR acted	Reset	14:00:00	16:30:00	2 times
2	OHP	CO 34	OLR acted	Reset	17:30:00	17:35:00	
3	OHP	TBS on co 21	PCRD O/T acted	Reset	16:10:00	16:25:00	
4	OHP	CO 26	OLR acted	Reset	21:45:00	21:55:00	
5	OHP	BRC on co 8a LT	PCRd O/T acted	Reset	20:50:00	21:05:00	
6	OHP	BRc on co 28 B/W2	One core got in Festoon cable	Reconnected it	17:45:00	19:30:00	
7	OHP	TBS on CO 22 Left Luff	OLR acted	Reset	16:30:00	16:50:00	
8	OHP	TBS on CO 7a	Right boom ZSS Probe	Replaced	16:15:00	16:40:00	
9	OHP	VF 1a	OLr acted	Reset	16:30:00	21:00:00	4 times
10	CHP	CC 54	OLR acted	Reset	16:10:00	16:50:00	2 Times
11	CHP	CC 131	OLR acted	Reset	17:30:00	21:30:00	2 Times
12	CHP	CC 51 a	OLR acted	Reset	21:20:00	21:30:00	
13	CHP	CC 29	OLR acted	Reset	21:05:00	21:10:00	
14	CHP	cC 109 ZSS	Belt slipping	Informed to oprn	15:00:00	15:15:00	
15	CHP	CC 32	OLR acted	Reset	20:25:00	20:35:00	
16	CHP	CC 15	OLR acted	Reset	21:55:00	22:00:00	

वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 22/10/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
17	CHP	SCr 10 On CC 105 B/C	Communication problem	LT done	21:45:00	22:00:00	
18	WT	OP2	Incomer1(LC 10a , 2a) tripped in LBDS	Bus-coupler made on	17:25:00	17:40:00	
19	WT	OT3	D1 trip	Reset	18:55:00	19:00:00	