



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 09/08/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO-6A	Reported no operation taking place	Wrong complaint	00:30:00	00:50:00	
2	OHP	WOBR on CO-29	B/C not running	Wrong complaint	01:10:00	01:20:00	
3	OHP	WOBR on CO-6A	Slewing not stopping	Stop button adjustment done and tested okay	00:50:00	01:00:00	Stop PB to be changed
4	OHP	CO-26	Reported tripped	OLR acted.Reset done	02:30:00 02:55:00	02:40:00 03:00:00	
5	CHP	SCR-1 on CC-33	LT not taking place	M-6 MPCB tripped.Made on and tested okay	03:00:00	03:10:00	
6	WT	OT-3	Reported tripped	D-1 tripped on encoder-43 fault.Reset done	23:50:00	23:55:00	
7	IOSA	OC-11A	Reported not healthy	Control fuse blown.PC cable earth fault.Field wire removed and software and hardware contacts bypassed and tested okay	04:00:00	04:35:00	