RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 18/10/2026

Area: OHP

Equipment	Job
hvmcc-1 to lc-4 PLC communication	Redundant line was not communicating, checked and found cable got cut in cable gallery near LC-4, re-joint done and restored communication.