RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 14/11/2026

Area: CHP

Equipment	Job
CC 126	Spare Motor Connected with 3 Phase supply to Improve IR value with rotor locked
LC 17, JH 19	Lighting Improved
CC 56	P/C kept in Circuit
LC 17 (CM 22)	Bus bar Maintenance done
COB 5 Stacking JHs	Hoist Maintenance done
CC 33, 112, 209, 210, 211, 212 , SCR-2, S3	PPM done