वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 13/11/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CR1A	stopped in vibration,gap adjustment problem	informed operation	22:45:00	23:00:00	
2	OHP	CO 25	OLR acted	reset	01:50:00	02:00:00	
3	CHP	CC 104 SCR9	slew not working,mccb tripped	reset and checked all found ok	03:40:00	03:50:00	
4	CHP	CC 131	motor tripped on OLR	reset	02:45:00	02:50:00	2 times
5	WT	OP4	no movement,D4 OLR acted	reset	00:10:00	00:25:00	