



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/07/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	olr acted	reset	22:35:00	22:40:00	4 times
2	OHP	brc on co 28	bc not running,olr acted	reset	01:45:00	02:00:00	
3	OHP	co 26	olr acted	reset	03:35:00	03:40:00	
4	OHP	wobr on co 29	LT not working.m3 tripped,due to jamming	m3 mpcb made on	03:45:00	04:00:00	
5	CHP	CC 131	Olr acted	Reset	00:30:00	00:35:00	
6	CHP	Scr 3 on CC 37	B/C olr acted	Reset	00:05:00	00:15:00	
7	CHP	Scr 2 On CC 33	LT drum sensor acted	Reset	01:40:00	01:50:00	
8	CHP	CC 31	Olr acted	Reset	04:10:00	04:15:00	