# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 15/10/2026

Area: CHP

| Equipment | Job |
|---|---|
| CC 53 | 4 nos PC switches wiring completed and kept in ckt |
| CC 13,17,24,51A | PPM done |
| CM 19 | Room cleaning done |
| SCR 8 | LT control earth fault isolated and kept end limit in ckt |
| SCR 1 | Boom position switch replaced and kept in ckt |
| S 3 | Shifted from CC 112 to repair bay |
| CC 38,SCR 6 | PPM was done |