वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 15/10/2026

Area: WT

Equipment	Job
OM 4 and OT 4 MCC	Panel Bus bar maintenance done
AF 5(O)	B phase lug replaced @ motor T B
OT 4 series	Motor side ppm done
OT 3 series	Motor side ppm done
OT 2 series	Motor side ppm done