



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	TRIPPED ON OLR	RESET DONE	00:22:00	00:28:00	
2	CHP	CC-104 SCR-6	SIGNAL MISSING	MACHINE LT DONE THEN OK	00:45:00	01:00:00	
3	CHP	CC-33 SCR-2	LT NOT WORKING PCRD OT ACTED	RELEASED	01:15:00	01:30:00	
4	CHP	CC-39 SCR-7	COMMUNICATION PROBLEM	LT DONE THEN OK ... MEANWHILE STREAM CHANGED BY CCR ... NOW COMMUNICATION STABLE	03:40:00	04:05:00	
5	CHP	LC-19	INCOMER -1TRIP	MADE ON	00:40:00	00:50:00	
6	CHP	CC-52	TRIPPED ON OLR	RESET DONE	05:53:00	06:00:00	