



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 04/06/2026

Area: WT

Equipment	Job
MIS	22KW SPARE MOTOR TESTED
OP-7	VFD FIXED IN MOTOR -5 AND TESTED ... ONE 24V RELAY ALSO CHANGED
EOT COAL	MOTOR AND PANEL SIDE PPM DONE