RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 05/11/2026

Area: OHP

Equipment	Job
brc-3 on co-34	shifted from co-34 to co-33m
brc-4 on co-8a	ct festoon cables loop adjusted. Logic modified such that Charge pressure ,accumulator pressure faults will now withdraw bucket wheel command, instead of stopping pump.
wobr-2 on co-29	pcrd cable wounded onto drum and shifted to repair bay. lighting and welding machine supply provided for repair bay jobs