वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 23/10/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 6A	no power,acb tripped	made it on	00:15:00	00:30:00	
2	OHP	TBS on co 22	luffing not working,olr acted	reset	02:36:00	02:48:00	
3	OHP	co 25	olr acted	reset	03:45:00	04:00:00	
4	CHP	CC 111 scr 4	b/c not running in stacking,selection in reclaiming	changed to stacking mode	01:15:00	01:25:00	
5	CHP	CC 35 stk2	b/c not working, mpd acted	reset	01:30:00	01:40:00	
6	CHP	cc 40 scr 7	b/c stopped in zss,coal piece stucked in cage	cage cleaned	04:45:00	05:00:00	
7	CHP	CC 52	mpd tripped 4 times	reset	02:50:00	02:56:00	
8	IOSA	OC 21A	BRS acted,mechanical moving part problem	mechanical brs adjusted and tightened	22:30:00	22:40:00	