# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 04/11/2026

Area: WT

| Equipment | Job |
|---|---|
| MIS | PLC MADE READY FOR LC-10A |
| OP-5 | TROLLEY LINE CHECKING AND PROBLEM RECTIFICATION DONE |
| CP-4 | REVERSE LIMIT STRIKER ADJUSTED |
| LC-10A | FEEDER 2 BUSBAR DUCT COVERED WITH TARPAULIN TO A AVOID WATER ENTRY |
| LC-10A | MAINTENANCE DONE |