



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/09/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO-6A (C)DRIVE	OLR ACTED	RESET DONE	06:10:00	06:20:00	
2	OHP	CO-34	TRIPPED ON OLR	RESET DONE	08:55:00	09:10:00	
3	CHP	CC-131	OLR ACTED	RESET DONE	13:25:00	13:30:00	
4	CHP	CC-40	TRIPPED ON OLR	RESET DONE	11:50:00	12:00:00	