



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/07/2026

Incharge(s): P Venkat Kiran,P Venkat Kiran

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-25	olr acted	reset done	07:10:00	07:20:00	
2	OHP	co 29	olr acted	reset done	08:30:00	08:50:00	
3	OHP	wobr-1 on co-26	slew not taking place.	limit got stuck, made free	12:00:00	12:15:00	
4	OHP	brc-1 on co-28	ct not taking place	BW got stuck with material, after clearing , CT took place	12:00:00	12:30:00	no electrical problem
5	OHP	co-50	olr acted	reset done	13:00:00	13:10:00	
6	CHP	CC 131	OLR acted	Reset	06:30:00	12:10:00	Three times
7	IOSA	L and T wobr on oc-18a	LT not taking place. pcrd Extra Over tension acted	cable released and observed LT operation	10:55:00	11:10:00	