



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/07/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	olr acted	reset	19:45:00	19:55:00	2 times
2	OHP	co 25	olr acted	reset	16:15:00	16:25:00	
3	OHP	TBS on co 22	all drive not working,control off	made it on	14:50:00	15:00:00	
4	CHP	CC 213	drive tripped	reset it	17:35:00	17:40:00	
5	CHP	CC 213 scr 9	slew not working,MCCB tripped	made it on	18:55:00	19:05:00	2 times
6	CHP	CC 32	mpd tripped	made it on	20:40:00	20:45:00	
7	CHP	CC 107	olr acted	reset	21:25:00	21:30:00	
8	CHP	CC 131	tripped on olr	reset	19:40:00	19:45:00	2 times
9	WT	OT 3	D1 tripped in encoder fault	reset	19:00:00	19:05:00	
10	IOSA	L and T WOBR	LT not working,OT acted	OT released	20:20:00	20:30:00	2 times