



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/07/2026

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-21	RBC OLR ACTED	RESET DONE	06:10:00	06:20:00	
2	OHP	WOBR ON CO-29	LUFFING OLR ACTED	RESET DONE	06:30:00	06:35:00	
3	OHP	TBS ON CO-5A	REPORTED LT NOT TAKING PLACE FOUND M-2 OLR ACTED (DUE TO MATERIAL JAMMING)	RESET DONE AND INFORM TO OPERATION	07:00:00	07:10:00	
4	OHP	CO-29	OLR ACTED	RESET DONE	07:10:00	07:20:00	
5	OHP	CO-8A	REPORTED CO-8A RED CHECKED AND FOUND 1-141LC-3 OM-29 I/C TRIP	I/C CHARGED THAN OK	09:10:00	09:20:00	
6	OHP	CC-52	MPD TRIP	RESET DONE	13:05:00	13:10:00	
7	OHP	CC-33 SCR-2	SLEW DRIVE TRIP	RESET DONE	12:35:00	12:50:00	
8	CHP	VS-3	OLR ACTED	RESET DONE	12:05:00	12:10:00	
9	CHP	CC-54	OLR ACTED	RESET DONE	08:20:00	08:30:00	
10	CHP	LC-19	I/C-1 TRIP	I/C-1 CHARGED THAN OK	08:10:00	08:20:00	
11	CHP	CC-215	CJD ACTED (2TIMES)	SENSOR CLEANED THAN OK	07:45:00	08:50:00	
12	CHP	CC-33 SCR-2	LT NOT TAKING PLACE DRIVE TRIP AND PCRD DRUM SENSOR ACTED	DRIVE RESET AND O/T RELEASED THAN OK	08:30:00	08:55:00	
13	CHP	CC-31 SCR-1	LT DRIVE TRIP	RESET DONE	13:25:00	13:40:00	
14	WT	OP-1	DRIVE-1 TRIP FAULT CODE 1. AC	RESET DONE	09:25:00	09:35:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/07/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	IOSA	OC-14A	REPORTED NOT HEALTHY FOUND R/R L/R PULL CHORD ACTED	BY-PASSED	11:30:00	11:40:00	
16	IOSA	OC-19A	BRS NOT RESET	AFTE3R MATERIAL CLEANED RESET DONE THAN OK	11:40:00	11:50:00	