



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 18/07/2026

Area: OHP

Equipment	Job
tt-4	motor and panel side ppm is done
tt-4	motor and panel side ppm is done
vf-10 m2	spare motor installed and trail run is taken.
vf-10 m2	spare motor installed and trail run is taken.
wobr - 3 on co-25	pcrd ot limit switch base bolts replaced, limit adjustment done. pcrd motor brake adjustment done,
wobr - 3 on co-25	pcrd ot limit switch base bolts replaced, limit adjustment done. pcrd motor brake adjustment done,
brc-2 on co-31	ct drive DBR connection path fuses damaged, cable insulation provided.
brc-2 on co-31	ct drive DBR connection path fuses damaged, cable insulation provided.
tbs-7 on co-19	ppm is done
tbs-7 on co-19	ppm is done
OCR HMI	primary server made ready, route issue rectified and restored redundancy to the HMI's
OCR HMI	primary server made ready, route issue rectified and restored redundancy to the HMI's
tbs-4 on co-5a	shifted from co-5a to co-21
tbs-4 on co-5a	shifted from co-5a to co-21
tbs-3 on co-21	shifted from co-21 to co-5a
tbs-3 on co-21	shifted from co-21 to co-5a