वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 26/10/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRc on CO 32	ACB in off condition	Made it on	15:20:00	15:35:00	
2	OHP	BRC on CO 8a	Lt M1 Trip	Reset	18:40:00	18:55:00	One Bhogi Derailed
3	CHP	CC 47	Selector switch in local mode	Changed to Remote	20:05:00	20:15:00	
4	CHP	CC 58	OLR acted	Reset	17:10:00	17:25:00	
5	CHP	CC 51	Feeding conv olr acted	Reset	21:10:00	21:15:00	