



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 30/06/2026

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-34	TRIPPED ON OLR	RESET DONE	00:00:00 23:45:00	00:10:00 23:55:00	
2	OHP	CO-25	TRIPPED ON OLR	RESET DONE	00:45:00	00:55:00	
3	OHP	TBS ON CO-21	RBC ZSS COMPLAINT	NO ELECTRICAL PROBLEM PULLEY SLIPPING	00:23:00	00:40:00	
4	OHP	CO-26	OLR ACTED	RESET DONE	03:50:00	04:00:00	
5	OHP	VF-22	YARD SIDE MOTOR PROBLEM	GIVEN IN ONE MOTOR	23:40:00	00:30:00	
6	CHP	CC-38 SCR-6	BC NOT RUNNING	30 DEGREE LIMIT ACTED BYPASSED	22:25:00	22:40:00	TO BE CHECKED
7	CHP	SCR-3 CC-37	LUFF NOT WORKING ... PCRD OT ACTED	MARTIAL JAMMING NEAR LIMITS AND SLEW AREA .. INFORMED FOR CLEANING PCRD OT RELEASED	04:20:00 05:40:00	04:30:00 05:50:00	
8	CHP	CC-58	TRIPPED ON OLR	RESET DONE	05:50:00	06:00:00	
9	WT	CO-3	TRIPPED ON OLR	RESET DONE	02:45:00 05:00:00 22:00:00	02:50:00 05:05:00 22:05:00	