



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/05/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO 30 CT	REV COMMAND CORE LOOSE IN DRIVE TERMINALS	CONNECTED PROPERLY	01:10:00	02:50:00	
2	OHP	CO 26	OLR ACTED	RESET	02:40:00	02:50:00	
3	OHP	WBR ON CO 25 LT	BREAK PROBLEM	INFORMED TO MECH	02:00:00	02:30:00	
4	CHP	CC 54	OLR ACTED	RESET	02:55:00	03:10:00	2 TIMES
5	CHP	SCR3 ON CC 37	LUFF OIL LEVEL LOW	INFORMED TO MECH	00:55:00	01:15:00	OIL LEAKAGE
6	CHP	SCR 3 ON CC 37 LT	DRIVE TRIPPED	RESET	05:35:00	05:45:00	
7	CHP	CC 51 TIS	OLR ACTED	RESET	01:25:00	01:35:00	
8	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	05:45:00	05:50:00	
9	IOSA	ALL CONV ARE RED	COMMUNICATION PROBLEM	POWER RECYCLED IN EACH LC THEN OK	01:25:00	02:10:00	