



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/10/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	olr acted	reset	02:57:00	03:09:00	
2	OHP	co 29	olr acted	reset	23:05:00	23:10:00	
3	OHP	CO 3B	not running, healthy	power recycle done	01:15:00	01:30:00	
4	CHP	CC 51	mpd acted	reset	05:35:00	05:40:00	