



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/10/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	olr acted	reset	16:00:00	16:10:00	
2	OHP	BRC on CO32	bc not running,zss cage interlock stucked with stone	cage made free	18:25:00	18:40:00	
3	OHP	VF 6	OLR acted	reset	19:00:00	19:15:00	
4	CHP	CC 52	control mcb tripped	reset	19:00:00	19:05:00	
5	CHP	Vs 1	tripped due ol	reset	18:30:00	18:45:00	
6	CHP	SCR2 on cc 33	b/w olr acted	reset	17:10:00	17:20:00	
7	CHP	SCR2 on CC33	b/c not running,signal problem	LT done than ok	20:40:00	21:00:00	
8	CHP	SCR7 on cc 40	B/c not running,acb tripped	made it on	20:30:00	20:40:00	