



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/09/2026

Shift: C

Incharge(s): Nagendra Midde,Lal Singh

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO 29 LT	M3 TRIP	RESET	22:50:00	23:10:00	
2	OHP	CO 25	OLR ACTED	RESET	22:55:00	05:00:00	3 TIMES
3	OHP	CO 16 HEALTHY STOPPING	POSITION SENSOR PROBLEM	PROPERLY ADJUSTED	04:50:00	05:00:00	
4	CHP	CC 125	OLR ACTED	RESET	05:20:00	05:25:00	