



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/05/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-41A	REPORTED BRS ACTING FREQUENTLY FOUND BELT PIECE HANGING	INFORMED TO OPERATION	09:20:00	09:30:00	
2	CHP	CC-52	MPD TRIP	RESET DONE	08:20:00	08:25:00	
3	CHP	CC-37 SCR-3	REPORTED B/C NOT RUNNING 30DEGREE LIMIT ACTED	SLEW DONE THAN OK	06:30:00	06:40:00	
4	CHP	CC-37 SCR-3	LT NOT TAKING PLACE M-3 TRIP	RESET DONE	06:30:00	06:40:00	
5	CHP	CC-31 SCR-1	LUFF NOT WORKING OLR ACTED	RESET DONE	07:05:00	07:15:00	
6	CHP	CC-125	MPD TRIP	RESET DONE	12:30:00	12:35:00	
7	WT	OT-3,DRIV E-2	SANTURATION-7 FAULT TRIP (3TIMES)	RESET DONE	08:00:00 10:45:00 11:10:00	08:05:00 10:50:00 11:15:00	