



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/05/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	00:00:00 01:20:00	00:10:00 01:30:00	
2	CHP	SCR 1 ON CC 31 LUFF	OLR ACTED	RESET	23:15:00	23:30:00	
3	CHP	SCR 6 ON CC 104 NO DRIVE RUNNING	RIO CONTROL MCB TRIP	MADE IT ON	02:35:00	02:55:00	
4	CHP	CC 131	OLR ACTED	RESET	00:05:00	00:10:00	
5	CHP	CC 54	OLR ACTED	RESET	01:55:00	02:00:00	
6	WT	OT3	D2 TRIP	RESET	23:05:00	23:15:00	
7	WT	CT2 REVERSE	JAMMING NEAR WHEELS	AFTER CLEANING OK	03:10:00	03:20:00	