



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 29/08/2026

Area: CHP

Equipment	Job
JH C 6	Hoist cable (10@2.5) replaced, terminations done and trail run was taken
CC 15,19	Running inspection was done
CC 116,117,TT	PPM was done
Stacker 3,SCR 1	11 nos 35W LED fixtures replaced and improved lighting. Damaged cables replaced
Hoist CT motor	Overhauling done and fixed in repair shop telfer and trail run was taken
S3,SCR 4	S3 shifted to CC 34, SCR 4 shifted to CC 112