



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/08/2026

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-11(C/D)	Reported not moving	MPCB tripped.Made on	08:15:00	08:25:00	
2	OHP	CO-37	Reported BRS acting frequently	Checked and found belt pieces hanging and acting BRS	11:48:00	12:10:00	Informed to operation
3	OHP	CO-25	Reported tripped	OLR acted.Reset done	06:35:00	06:45:00	
4	CHP	CC-33 S-2	TUL CS acted	Acted due to rain.Bypassed as per operation request	12:30:00	12:42:00	
5	CHP	CC-112 SCR-8	NO drives working	Incomer tripped.Made on	12:55:00	13:10:00	
6	CHP	CC-28 FG	Reported not working	OLR acted.Reset done	09:00:00	09:10:00	
7	CHP	CC-131	Reported tripped	OLR acted.Reset done	11:04:00	11:10:00	