



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/08/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 26	b/c not running,cs acted	sensor cleaned and sensitivity adjusted	21:10:00	21:30:00	
2	OHP	wobr on co 25	LT not working,OT acted,PCRD chain broken	informed mechanical	19:00:00	19:10:00	
3	CHP	CC 54	mpd tripped	made it on	21:10:00	21:20:00	
4	CHP	CC 112 SCR8	b/c stopped in ZSS,probe damaged	ZSS bypassed,	18:10:00	18:30:00	now probe replacement going on
5	CHP	CC 40 SCR7	b/c stopped in zss,coal piece stucked	cage made free	21:35:00	21:45:00	
6	WT	OP6	no movement,l/C tripped in LC2B	made it on	19:00:00	19:20:00	