



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/09/2026

Shift: C

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment              | Problem                         | Action                     | From     | To       | Remarks |
|-------|------|------------------------|---------------------------------|----------------------------|----------|----------|---------|
| 1     | OHP  | WBR on CO 25           | OLD HT joint Opened             | Joint done b DNW           | 22:00:00 | 02:00:00 |         |
| 2     | OHP  | BRC on CO 28 B/W 1     | OLR acted                       | Reset                      | 00:20:00 | 00:40:00 |         |
| 3     | OHP  | TBS on CO 5a LT        | M1 , M4 trip due to break stuck | Reset and Informed to Mech | 01:45:00 | 02:00:00 |         |
| 4     | OHP  | BRC on CO 30 B/C       | OLR acted                       | Reset                      | 02:40:00 | 03:00:00 |         |
| 5     | OHP  | TBS on co 19 Left Luff | OLR acted                       | Reset                      | 04:30:00 | 04:45:00 |         |
| 6     | OHP  | CO 26                  | Olr acted                       | Reset                      | 02:05:00 | 04:45:00 | 3 times |
| 7     | OHP  | RSCO 6a                | OLR acted                       | Reset                      | 02:45:00 | 05:55:00 | 3 times |
| 8     | OHP  | CR 3a                  | Hydraulic Pump MPCB Trip        | Made it on                 | 04:30:00 | 05:10:00 |         |
| 9     | CHP  | SCR 3 on CC 37         | B/C Olr acted                   | Reset                      | 00:30:00 | 04:45:00 | 2 times |
| 10    | CHP  | SCR 6 on CC 38 Slew    | Limits Common High Mcb Tripped  | Made it on                 | 01:20:00 | 01:40:00 |         |
| 11    | CHP  | SCR 2 on CC 33 B/C     | OLR acted                       | Reset                      | 03:15:00 | 03:30:00 |         |
| 12    | CHP  | SCR 9 on CC 104        | ACB trip                        | Made it on                 | 04:00:00 | 04:20:00 |         |
| 13    | CHP  | CC 112 DE              | C/S bypassed                    | Due to Rain                | 02:00:00 | 02:10:00 |         |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/09/2026

Shift: C

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment     | Problem             | Action                                  | From     | To       | Remarks |
|-------|------|---------------|---------------------|-----------------------------------------|----------|----------|---------|
| 14    | CHP  | CC 28 T/T C/S | Probe Cable Problem | bypassed and Replacement under Progress | 04:00:00 | 06:00:00 |         |
| 15    | WT   | CO 3          | OLR acted           | Reset                                   | 22:10:00 | 00:40:00 | 2 times |