RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 06/11/2026

Area: WT

Equipment	Job
CP 2	Panel and Motor side ppm done,D3 and 4 cascade contactor replaced
CP 4	Trolley line inspection done ,found cable damaged @col no 58, isolated
CC 7,8 and 9	Tunnel , CC 2 ,3 and AF level lighting inspection done