वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 10/11/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	Co 26	olr acted	reset	03:00:00	03:15:00	
2	CHP	CC 112 S3	b/c not running,mpd acted	reset	22:20:00	22:30:00	
3	CHP	CC 112 s3	LT reverse not working,pcrd OT acted	released	01:20:00	01:30:00	
4	CHP	CC 32 scr5	LT not working,OT acted	OT released	02:50:00	03:05:00	
5	CHP	cc 131	motor tripped in olr	reset	05:10:00	05:15:00	
6	WT	OP2	no movement,D1 olr acted	reset	03:30:00	03:45:00	