



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/05/2026

Area: CHP

Equipment	Job
SCR 5	Instrumentation sensors maintenance was done
CC 116,117,TT	New control cable added and laid up to panel,connections to be done.TT inputs wired up to IO rack
CC 32,37,39,SCR 3,4,7	Running inspection was done
JH C 209,210,211	6 nos 30W LED lamps provided and improved lighting
CC 41/42 tail end	Sump pump replaced and de watering done.MPCB Provided
CC 13,17,24,29,35,Stacker 1	PPM was done