



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	olr acted	reset	06:45:00	06:55:00	3 times
2	OHP	BRC on Co 8A	CT not working,chain problem	informed mechanical	09:05:00	09:15:00	
3	CHP	CC 32 SCR4	slew not working	fault reset done in operator cabin	07:15:00	07:25:00	
4	CHP	CC 40 SCR 6	LT not working,pcrd cable fallen,OT acted	cable rewinding	08:55:00	10:10:00	
5	CHP	CC 125	mpd acted	reset	12:25:00	12:35:00	
6	CHP	CC 9	healthy stop,	run in local than kept in PLC than ok	06:45:00	06:55:00	
7	CHP	CC 22	red,PB stucked	PB released	09:00:00	09:05:00	