



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/09/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 29	olr acted	reset	22:25:00	22:30:00	
2	OHP	co 26	olr acted	reset	22:09:00	22:15:00	
3	CHP	scr 8 on cc 112	b/c not working, chute jamming,CS acted	informed operation	23:50:00	00:10:00	
4	CHP	SCR 8 on cc112	luff not working,spark observed contactor problem	contactor replaced with spare one	00:30:00	02:30:00	
5	CHP	cc 35 S2	b/c not working, tripped in UNB fault	reset, and current checked in 3 phase, cable checked @ motor TB, panel	23:50:00	00:05:00	6 times ,to be checked in G shift