वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 02/11/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	olr acted	reset	18:15:00	18:25:00	3 times
2	OHP	brc on co 8A	b/w stopping in ZSS fault	checked and found in 8s working fine ,problem in 4sand 6s	20:05:00	20:25:00	to be checked in G shift
3	CHP	CC 40 scr7	luff not working,mpd ol acted	reset	19:25:00	19:35:00	
4	CHP	cc 37 scr3	b/c not running,c/s acted due to jamming	informed to operation	21:20:00	21:30:00	