



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CR 2 and 3	oil flow not healthy	reset	00:30:00	00:40:00	
2	OHP	wobr on co 29	LT not working,OT acted	OT released,informed mechanical guide problem	22:35:00	22:50:00	
3	OHP	CO 32 BRC	bw 1 not running,pump electrical not healthy,mcb tripped	made it on	23:45:00	23:59:00	
4	OHP	co 26	olr acted	reset	05:20:00	05:30:00	
5	CHP	C C 37 scr 3	bc not running ,mpd tripped	reset	04:30:00	04:35:00	
6	CHP	CC 51	mpd acted, 2 times	reset	04:15:00	04:20:00	
7	CHP	SCR 2 on cc33	LT not working,LT not working,pcrd OT acted,slackness acted,PCRD healthy not coming	main contactor on bit bypassed,slackness bypass,chain problem mechanical problem	03:50:00	04:50:00	