



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/08/2026

Incharge(s): Nagendra Midde,K SANKARA RAO

Shift: B

| Sl No | Area | Equipment            | Problem            | Action     | From                 | To                   | Remarks |
|-------|------|----------------------|--------------------|------------|----------------------|----------------------|---------|
| 1     | OHP  | CO-26                | OLR ACTED (2TIMES) | RESET DONE | 15:15:00<br>18:45:00 | 15:25:00<br>18:55:00 |         |
| 2     | OHP  | CO-25                | OLR ACTED          | RESET DONE | 19:10:00             | 19:20:00             |         |
| 3     | OHP  | RSCO-6A<br>(C) DRIVE | OLR ACTED          | RESET DONE | 15:00:00             | 15:20:00             |         |