



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/09/2026

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	TRIPPED ON OLR	RESET DONE	15:05:00 16:00:00 18:25:00	15:15:00 16:10:00 18:45:00	
2	OHP	BRC on CO-31	Machine derailed	Assisted mechanical	19:00:00	21:30:00	
3	CHP	SCR 2 ON CC 33	SLEW NOT TAKING PLACE	TRIPPED ON OBF FAULT/RESET DONE	19:00:00	19:15:00	