



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/05/2026

Incharge(s): Lal Singh

Shift: C

| Sl No | Area | Equipment    | Problem                                      | Action                                                                                                                     | From                 | To                   | Remarks |
|-------|------|--------------|----------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|----------------------|----------------------|---------|
| 1     | OHP  | CO-16        | TRIPPED ON OLR                               | RESET DONE                                                                                                                 | 03:15:00<br>03:50:00 | 03:25:00<br>04:00:00 |         |
| 2     | OHP  | CO-32 BRC    | PUMP STOPPING ON CHARGE PRESSURE             | MOTOR AND PUMP NOT ENGAGING .. BOTH SIDE COUPLING AND SPIDER DAMAGED . NEW COUPLING FIXED IN MOTOR MECHANICAL JOB GOING ON | 23:00:00             | 06:00:00             |         |
| 3     | CHP  | CC-104 SCR-6 | BC NOT RUNNING ... CJD ACTED DUE TO MOISTURE | CJD BYPASSED                                                                                                               | 04:50:00             | 05:05:00             |         |
| 4     | CHP  | LC-19        | INCOMER -1 TRIPPED                           | RESET                                                                                                                      | 02:00:00             | 02:15:00             |         |
| 5     | CHP  | CC-131       | MPD TRIPPED 2 TIMES                          | RESET DONE                                                                                                                 | 02:50:00             | 05:00:00             |         |
| 6     | CHP  | CC-130       | TIS TRIPPED                                  | RESET DONE                                                                                                                 | 00:30:00             | 00:40:00             |         |