RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 25/10/2026

Area: OHP

Equipment	Job
brc-1 on co-31	shifted to co-30
wobr-4 on co-6a	Charge and Accumulator pressure faults stopping of Hydraulic pump interlock is modified to stop bw or slew command . trail run is done.
co-34 brs	restored both mechanical and electronic brs in series to circuit.