



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/09/2026

Shift: C

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 34a	ZSS acting due to belt slipping	Informed to oprn	03:30:00	03:45:00	
2	OHP	TBS on CO 21 LT	M1 trip	Reset	03:10:00	03:30:00	
3	OHP	WBR on co 26	Incomer tripped in lbds 5 due to Heavy moisture in I/O panel	Hot blowing done	22:00:00	01:00:00	
4	OHP	WBR on co 26 b/c	PLC Power recycled	Then OK	03:30:00	04:00:00	
5	OHP	CO 7A ZSS	Probe Damaged	Replaced	03:50:00	04:30:00	
6	OHP	WBR on CO 25 LT	M3 trip Due to Track Jamming	Informed to Oprn	01:30:00	02:00:00	
7	OHP	OP 5, 6	Power TRipped	Made it on	23:00:00	00:30:00	3 times
8	CHP	CC 29	Control MCB tripping due to Earth fault in C/S	RL 1 to RL 2 loop given	03:30:00	04:00:00	
9	CHP	Scr 7 on CC 40 LT	Drive Trip	Reset	22:30:00	22:40:00	
10	CHP	SCR 1 ON CC 31	B/C ZSS	Bypassed	02:00:00	02:15:00	
11	CHP	SCR 5 On CC 32	One HT Fuse blown	Checking under Progress	01:00:00	06:00:00	
12	CHP	SCR 8 on CC 112	VCB trip on Machine	Made it on	05:00:00	06:00:00	
13	CHP	CC 52 C/S	Probe got cut	Rejoined	01:10:00	01:20:00	
14	CHP	RG1	CTMF fault	Reset	23:05:00	23:15:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/09/2026

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	WT	OP 9	Power Tripped	Made it on	03:00:00	03:10:00	
16	WT	OP2	Breaker Tripped	Made it on	23:30:00	23:40:00	