



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/06/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	01:40:00 02:45:00	01:50:00 02:55:00	
2	OHP	CO 29	OLR ACTED	RESET	05:05:00 05:40:00	05:10:00 05:50:00	
3	OHP	BRC ON CO 30	EMERGENCY STOP CONNECTION LOOSE	TIGHTENED	22:55:00	23:20:00	
4	OHP	CO 67	OLR ACTED	RESET	05:35:00	05:40:00	
5	OHP	OP7	BREAKER TRIPPED	RESET	05:10:00	05:20:00	
6	CHP	SCR 2 ON CC 33 LT	PCRD DRUM SENSOR ACTED	RESET	22:55:00	23:15:00	
7	CHP	SCR 1 ON CC 31 SLEW	DRIVE TRIP	RESET	01:50:00	02:00:00	
8	CHP	SCR 7 ON CC 40 LUFF	DOWN LIMIT ACTED	INFORMED TO OPRN	03:45:00	03:55:00	
9	CHP	CO 28	OLR ACTED	RESET	23:20:00	00:10:00	2 TIMES
10	CHP	CC 52	FEEDING CONV OLR ACTED	RESET	01:45:00	01:50:00	