



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/07/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-12A	zss acted	zss is acting due to belt overload, material removed and started.	11:50:00	12:00:00	no electrical problem
2	OHP	BRC on CO8A	CT not working,drive tripped	reset	10:55:00	11:10:00	
3	OHP	CO 26	olr acted	reset	11:25:00	11:35:00	
4	CHP	cc 51	mpd acted	reset	12:25:00	12:30:00	
5	IOSA	OC 11A	healthy stop,	checked found all ok	07:20:00	07:35:00	
6	IOSA	OC 4A	PC acted due to material fall on rope	PC released	07:20:00	07:40:00	