



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/07/2026

Shift: B

Incharge(s): P Venkat Kiran,P Venkat Kiran

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr-3 on co-25	It not taking place	pcrd overtension acted, released.	14:30:00	14:50:00	
2	OHP	tbs-4 on co-5a	no drives starting	Control MCB was tripping as control bus termination screw was touching to back plate. proper tightening done and insulation provided.	18:30:00	19:30:00	
3	OHP	wobr-2 on co-29	luff not taking place	tripped on olr twice , reset done	18:00:00 19:30:00	18:15:00 19:45:00	
4	OHP	co-111	tripped on olr twice due to jamming at receiving chute	informed mechanical , operation and reset done.	15:00:00 19:15:00	15:15:00 19:30:00	
5	OHP	rsco-6a belt drive	tripped on olr	reset done	15:20:00	15:30:00	
6	CHP	CC 125	Olr acted	Reset	16:30:00	16:40:00	
7	CHP	Cc 103 T/T	F/G trip	Reset	14:30:00	14:40:00	
8	CHP	SCR 9 on CC 213	Communication Problem	LT done	15:30:00	15:45:00	