



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/07/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-7	OLR ACTED	RESET DONE	12:25:00	12:50:00	
2	CHP	CC-215	OLR ACTED (4TIMES)	RESET DONE	07:50:00	10:40:00	
3	CHP	CC-107	OLR ACTED	RESET DONE	12:45:00	12:50:00	
4	CHP	CC-38 SCR-6	REPORTED SLEW AND B/W NOT RUNNING FOUND CP ACTED	INFORMED TO MECHANICAL	12:30:00	12:45:00	
5	CHP	CC-40 SCR-7	B/C OLR ACTED	RESET DONE	13:15:00	13:20:00	
6	CHP	CC-52	MPD TRIP	RESET DONE	13:35:00	13:40:00	
7	CHP	SCR-7	MODEM REMOVED FROM SCR-9 IN NIFHT KEPT IN SCR-7 .. DIDNOT WORK	MODEM REMOVED FROM S-3 IN R-BAY AND KEPT IN SCR-7 AND TESTED	08:00:00	09:30:00	