



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/04/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR 1 ON CO 29 LT	PCRD CABLE GOT STUCK	HT POWER MADE OFF AND CABLE MADE FREE	08:45:00	09:45:00	
2	CHP	SCR 3 ON CC 37 SLEW	PIPE GOT BURST	INFORMED TO MECH	12:00:00	12:20:00	
3	CHP	CC 201	OLR ACTED	RESET	10:35:00	10:45:00	
4	CHP	CC 222	P/C ACTED	BYPASSED	07:40:00	07:50:00	
5	CHP	CM 28	24 V DC PROBLEM	RECTIFIED	13:00:00	13:45:00	
6	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	08:30:00	09:25:00	2 TIMES