



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/04/2026

Area: CHP

Equipment	Job
Lighting	GPL point, one 350w LED fixed
JH-3	Hoist limits kept in circuit
CC-103 AND TT	PPM work done
CC 204 to212	PPM was done
SCR 2	LT motors alignment done and direction checked. Boom motor alignment completed.
CC 117	Receiving chute vibrator replaced and kept in service
CC 53	Drive changed to OCR side,termination done and trail run was taken